

155.01 ADOPTION OF FUEL GAS CODE. That a certain document, being marked and designated as the *National Fuel Gas Code*, 2015 edition, as published by the National Fire Protection Association®, published by the National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471, be and is hereby adopted as the Fuel Gas Code of the **City of Indianola, Iowa**, for regulating and governing the installation of fuel gas piping systems, appliances, equipment, and related accessories; and each and all of the regulations, provisions, penalties, conditions and terms of said Fuel Gas Code are hereby referred to, adopted, and made a part hereof, as if fully set out in this legislation, with the additions, insertions, deletions and changes, if any, prescribed in Section 155.02.

155.02 AMENDMENTS, MODIFICATIONS, ADDITIONS AND DELETIONS. The following sections of the *National Fuel Gas Code*, 2015 edition, as published by the National Fire Protection Association®, are hereby revised:

Delete Code Section: NFPA 54: 5.6.3.4

Replace with the following language:

5.6.3.4 Corrugated Stainless Steel. Only CSST with an Arc Resistant Jacket or Covering System listed in accordance with ANSI LC-1 (Optional Section 5.16)/CSA 6.26-2016 shall be installed in accordance with the terms of its approval, the conditions of listing, the manufactures instructions and this code including electrical bonding requirements in Section 7.13.2. CSST shall not be used for through wall penetrations from the point of delivery of the gas supply to the inside of the structure. CSST shall not be installed in locations where subject to physical damage unless protected in an approved manner.