



— FIRE DEPARTMENT —

## KNOX BOX MOUNTING REQUIREMENTS

1. The Knox Box shall be either Model 3200 or Model 4400 hinged in either recessed or surface mount configuration.
2. The Knox Box shall be installed 48” to 72” in height measured from the ground to the top of the box.
3. The Knox Box shall be installed within 72” to either side of the Main Entrance or the addressed side of the building.
4. The Knox Box must be bolted, not glued in place, follow the manufacturer’s instructions for installation.
5. If the Knox Box is a surface mount type box, apply caulking to the top, left, and right side. Do not caulk the bottom.
6. Ensure that the Knox Box you have purchased is specific to the City of Indianola.
7. Save all stickers that come with the box and give them to the Fire Code Official for installation.
8. Provide all keys and combinations required by the Fire Code Official. Examples of keys may include Master Keys, Fire Alarm Panel keys, Fire Pull Station keys, and Access Cards.
9. Deviation from the above mounting requirements shall be approved by the Fire Code Official prior to installation.

Additional information on the Knox Box can be obtained from their website: <https://www.knoxbox.com/>

*Last Revised: 05/08/2019*